

Our Ref: USSRA/L1/fw

5 October 2018

T: 01257 488000
E: polymeric.technical.uk@iko.com
www.ikogroup.co.uk

Dear Sir


Re:- Roof Angel

Further to our recent testing of the "Plascoat" PVC coated baseplate I can confirm that the results of our testing was satisfactory and therefore can confirm that we will endorse the use of Roof Angel/Plascoat PVC80GS products with IKO Armourplan products.

As with all Armourplan hot air welded laps & details, the welding can only be carried out by operatives who hold current approval status.

If you have any queries, please do not hesitate to contact either myself or the Technical Services Department, on the numbers below.

Yours faithfully
for and on behalf of
IKO Polymeric



Frank Williamson F.I.o.R.
Technical Services Manager

Technical Services Department: 01257 488012

Enc: