

# Declaration of Conformity

22<sup>nd</sup> January 2019

Bettersafe International BV declare that the:

Guard Angel Guard Rail System

As tested on:

21<sup>st</sup> January 2019

By:

Bettersafe International BV  
Witness A.Harris

Passed the following tests:

EN 13374:2013 Class B

Specific requirements are placed on the installation up to 30degree pitch.


Further details are on the following pages. Additional information available if required.

Steve Jervis  
Development Director

A handwritten signature in blue ink, appearing to read "Steve Jervis", is located below the printed name and title.


EN13374:2013 Class B

Roof Pitch up to 30deg.  
Roof Type: Trapezoidal



EN13374:2013 Class B

Roof Pitch up to 30deg.  
Roof Type: Standing Seam



EN13374:2013 Class B

Roof Pitch up to 30deg.  
Roof Type: Trapezoidal  
Standing Seam

